

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



CERTIFICATE OF COMPLIANCE

| | |
|--------------------|--------------------------|
| Project Name: | Enforcement Agency: |
| Dwelling Address: | Permit Number: |
| City and Zip Code: | Permit Application Date: |

This compliance document is only applicable to simple alterations that do not require field verification for compliance. When field verification is required, a CF1R-ALT-01 shall first be registered with a ECC-Provider Data Registry.

Alterations to Space Conditioning Systems that are exempt from field verification requirements may use the CF1R-ALT-05 and CF2R-ALT-05 Compliance Documents. Possible exemptions from duct leakage testing include: less than 25 feet (ft) of ducts were added or replaced; or the existing duct system was insulated with asbestos; or the existing duct system was previously tested and passed by a ECC Rater. If space conditioning systems are altered and are not exempt from field verification, then a CF1R-ALT-02 must be completed and registered with a ECC Provider Data Registry.

Alterations that utilize closed cell Spray Polyurethane Foam (ccSPF) with a density of 1.5 to less than 2.5 pounds per cubic foot having an R-value greater than 5.8 per inch, or open cell Spray Polyurethane Foam (ocSPF) with a density of 0.4 to less than 1.5 pounds per cubic foot having an R-value of 3.6 per inch, shall complete and register a CF1R-ALT-01 with a ECC-Provider Data Registry.

If more than one person has responsibility for installation of the items on this certificate, each person shall prepare and sign a certificate applicable to the portion of construction for which they are responsible. Alternatively, the person with chief responsibility for construction shall prepare and sign this certificate for the entire construction. All applicable Mandatory Measures shall be met. Temporary labels shall not be removed before verification by the building inspector.

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE JECC FIELD VERIFICATION



A. General Information

| Field | Field Name | Data Entry |
|-------|---|--|
| 01 | Project Name | |
| 02 | Date Prepared | |
| 03 | Project Location | |
| 04 | Building Front Orientation (deg or cardinal) | |
| 05 | CA City | |
| 06 | Number of Altered Dwelling Units | |
| 07 | Zip Code | |
| 08 | Fuel Type | |
| 09 | Climate Zone | |
| 10 | Total Conditioned Floor Area (ft ²) | |
| 11 | Building Type | Single Family |
| 12 | Slab Area (ft ²) | |
| 13 | Project Scope | Select as many as are applicable from the list: <input type="checkbox"/> Insulation (tables B, C & D) <input type="checkbox"/> Roof Replacement >50% (table E & B) <input type="checkbox"/> Space Heating System (Table J) <input type="checkbox"/> Space Cooling System (Table J) <input type="checkbox"/> Space Conditioning Duct System (Table J) <input type="checkbox"/> Water Heating (Table K) <input type="checkbox"/> Adding Fenestration/Glazing (Tables F & G) <input type="checkbox"/> Adding Fenestration/Glazing ≤16 ft ² Skylight (Tables F & G) <input type="checkbox"/> Replacing Fenestration/Glazing (Tables F and H) <input type="checkbox"/> Replacing Fenestration/Glazing ≤ 75 ft ² Windows (Tables F & H) <input type="checkbox"/> Replacing Fenestration/Glazing Skylight (Tables F & H) <input type="checkbox"/> Opaque Exterior Doors (Table I) |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



B. Opaque Surface Details - Framed (Section 150.2(b)1)

Note:

Where insulation is installed above the roofing membrane, or above the layer used to seal the roof from water penetration, the insulation shall have a maximum water absorption of 0.3 percent by volume when tested according to American Society for Testing and Materials (ASTM) Standard C272.

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|--|--------------|--------------|--------------|
| 01 | Tag/ID | | | |
| 02 | Assembly Type | | | |
| 03 | Frame Type | | | |
| 04 | Frame Depth (inches) | | | |
| 05 | Frame Spacing (inches) | | | |
| 06a | Proposed Cavity R-value | | | |
| 06b | Proposed Continuous Insulation R-value | | | |
| 07 | Proposed U-Factor | | | |
| 08 | Required U-Factor from Table 150.1-A | | | |
| 09 | Comments | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



C. Opaque Surface Details – Nonframed

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|--|--------------|--------------|--------------|
| 01 | Tag/ID | | | |
| 02 | Assembly Type | | | |
| 03 | Assembly Materials | | | |
| 04 | Thickness (inches) | | | |
| 05 | Proposed Core Insulation R-value | | | |
| 06a | Proposed Cavity R-value | | | |
| 06b | Proposed Continuous Insulation R-value | | | |
| 07 | Proposed U-Factor | | | |
| 08 | Required U-Factor or R-Value | | | |
| 09 | Comments | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



D. Opaque Surface Details – Masonry/Mass Walls

Note:

When insulation is added to the outside of a mass wall and/or when the inside is furred and insulated, the performance data may be adjusted using Equation 4-4 in the Reference Appendices, Joint Appendix, JA4.

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|---|--------------|--------------|--------------|
| 01 | Tag/ID | | | |
| 02 | Above or Below Grade? | | | |
| 03 | Proposed Masonry/Mass Wall Type | | | |
| 04 | Proposed Mass Thickness (inches) | | | |
| 05 | Proposed Exterior Insulation - R-Value | | | |
| 06 | Proposed Exterior Insulation - U-Factor | | | |
| 07 | Proposed Interior Insulation - R-value | | | |
| 08 | Proposed Interior Insulation - U-Factor | | | |
| 09 | Required Exterior Insulation - R-value | | | |
| 10 | Required Exterior Insulation - U-Factor | | | |
| 11 | Required Interior Insulation - R-Value | | | |
| 12 | Required Interior Insulation - U-Factor | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



E. Roof Replacement (Section 150.2(b)1)

Notes:

- Roof area covered by building integrated photovoltaic (PV) panels and solar thermal panels are exempt from the above Cool Roof requirements.
- Liquid field applied coatings must comply with installation criteria from Section 110.8(i)4.

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|---|------------------------------|------------------------------|------------------------------|
| 01 | Tag/ID | | | |
| 02 | Method of Compliance | | | |
| 03 | Roof Pitch | | | |
| 04 | Exception | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 05 | CRRC Product ID Number | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 06 | Product Type | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 07 | R-value Deck Insulation | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 08 | Proposed Initial Solar Reflectance | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 09 | Proposed Aged Solar Reflectance | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 10 | Proposed Thermal Emittance | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 11 | Proposed SRI (Optional) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 12 | Minimum Required Aged Solar Reflectance | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 13 | Minimum Required Thermal Emittance | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 14 | Minimum Required SRI (Optional) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



F. Fenestration/Glazing Allowed Areas and Efficiencies (Section 150.2(b)1A)

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|---|------------------------------|------------------------------|------------------------------|
| 01 | Alteration Type | | | |
| 02 | Maximum Allowed Fenestration Area for All Orientations (ft ²) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 03 | Maximum Allowed West-Facing Fenestration Area Only (ft ²) | | | |
| 04a | Existing Fenestration Area for All Orientations (ft ²) | | | |
| 04b | Existing West-Facing Fenestration Area (ft ²) | | | |
| 05a | Maximum Allowed U-factor (Windows) | | | |
| 05b | Maximum Allowed U-factor (Skylights) | | | |
| 06a | Maximum Allowed SHGC (Windows) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 06b | Maximum Allowed SHGC (Skylights) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 07 | Comments: | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



G. Fenestration Proposed Areas and Efficiencies – Add (Section 150.2(b)1A)

Note: Doors with greater than or equal to 25 percent glazed area are considered glazed doors and are treated as fenestration products.

Table G-1

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|---|------------------------------|------------------------------|------------------------------|
| 01 | Tag/ID | | | |
| 02 | Fenestration Type | | | |
| 03 | Frame Type | | | |
| 04 | Dynamic Glazing | | | |
| 05 | Orientation N, S, W, E | | | |
| 06 | Number of Panes | | | |
| 07 | Proposed Fenestration Area (ft ²) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 08 | Proposed West Facing Fenestration Area (ft ²) | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 09 | Proposed U-factor | | | |
| 10 | Proposed U-factor Source | | | |
| 11 | Proposed SHGC | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |
| 12 | Proposed SHGC Source | | | |
| 13 | Exterior Shading Device | | | |
| 14 | Combined SHGC from CF1R-ENV-03 | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



Table G-1

| Field | Field Name | Data Entry |
|-------|--|------------------------------|
| 15 | Total: Existing + Proposed Fenestration Area | |
| 16 | Maximum Allowed Fenestration Area | |
| 17 | Compliance Statement: Existing + Proposed Fenestration Area ≤ Maximum Allowed Fenestration Area | |
| 18 | Total: Existing + Proposed West-Facing Fenestration Area | <input type="checkbox"/> N/A |
| 19 | Maximum Allowed West-Facing Fenestration Area | <input type="checkbox"/> N/A |
| 20 | Compliance Statement: Total: Existing + Proposed West-Facing Fenestration Area ≤ Maximum Allowed West-Facing Fenestration Area | |
| 21 | Proposed Fenestration U-factor (Windows) | <input type="checkbox"/> N/A |
| 22 | Required Fenestration U-factor (Windows) | |
| 23 | Compliance Statement: Proposed Fenestration U-factor ≤ Required Fenestration U-factor | |
| 24 | Proposed Fenestration SHGC (Windows) | <input type="checkbox"/> N/A |
| 25 | Required Fenestration SHGC (Windows) | <input type="checkbox"/> N/A |
| 26 | Compliance Statement: Proposed Fenestration SHGC ≤ Required Fenestration SHGC | |
| 27 | Proposed Fenestration U-factor (Skylights) | <input type="checkbox"/> N/A |
| 28 | Required Fenestration U-factor (Skylights) | |
| 29 | Compliance Statement: Proposed Fenestration U-factor ≤ Required Fenestration U-factor | |
| 30 | Proposed Fenestration SHGC (Skylights) | <input type="checkbox"/> N/A |
| 31 | Required Fenestration SHGC (Skylights) | |
| 32 | Compliance Statement: Proposed Fenestration SHGC ≤ Required Fenestration SHGC | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



H. Fenestration/Glazing Proposed Areas and Efficiencies – Replace (Section 150.2(b)1B)

Note: Doors with greater than or equal to 25 percent glazed area are considered glazed doors and are treated as fenestration products.

Table H-1

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|-----------------------------------|------------------------------|------------------------------|------------------------------|
| 01 | Tag/ID | | | |
| 02 | Fenestration Type | | | |
| 03 | Frame Type | | | |
| 04 | Dynamic Glazing | | | |
| 05 | Orientation N, S, W, E | | | |
| 06 | Area Removed (ft ²) | | | |
| 07 | Area Added (ft ²) | | | |
| 08 | Net Added Area (ft ²) | | | |
| 09 | Proposed U-factor | | | |
| 10 | Proposed U-factor Source | | | |
| 11 | Proposed SHGC | | | |
| 12 | Proposed SHGC Source | | | |
| 13 | Exterior Shading Device | | | |
| 14 | Combined SHGC from CF1R-ENV-03 | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A | <input type="checkbox"/> N/A |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



Table H-2

| Field | Field Name | Data Entry |
|-------|---|---|
| 15 | Net Added West-facing Fenestration Area | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 16 | Is Net Added Fenestration Area ≤ for west-facing fenestration? | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| 17 | Net Added Fenestration Area (all orientations) | |
| 18 | Is Net Added Fenestration Area ≤ 0 for all orientations? | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| 19 | Proposed Fenestration U-factor (Windows) | <input type="checkbox"/> N/A |
| 20 | Required Fenestration U-factor (Windows) | |
| 21 | Compliance Statement: Is the proposed Fenestration U-factor ≤ the Required Fenestration U-factor? | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 22 | Proposed Fenestration SHGC (Windows) | <input type="checkbox"/> N/A |
| 23 | Required Fenestration SHGC (Windows) | |
| 24 | Compliance Statement: Is the Proposed Fenestration SHGC ≤ the Required Fenestration SHGC? | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 25 | Proposed Fenestration U-factor (Skylights) | <input type="checkbox"/> N/A |
| 26 | Required Fenestration U-factor (Skylights) | |
| 27 | Compliance Statement: Is the proposed Fenestration U-factor ≤ the Required Fenestration U-factor? | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 28 | Proposed Fenestration SHGC (Skylights) | <input type="checkbox"/> N/A |
| 29 | Required Fenestration SHGC (Skylights) | |
| 30 | Compliance Statement: Is the Proposed Fenestration SHGC ≤ the Required Fenestration SHGC? | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



I. Opaque Swinging Doors to Exterior (Section 150.1(c)5)

Notes:

- Any door with 25 percent or more glass is counted as a fenestration product in Tables F, G and H.
- Do not include fire-rated doors between garage or unconditioned space and conditioned space.
- If using weighted average to achieve required maximum U-factor, attach CF1R-ENV-02-E.

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|---------------------------|--------------|--------------|--------------|
| 01 | Tag/ID | | | |
| 02 | Area | | | |
| 03 | Proposed U-factor | | | |
| 04 | Proposed U-factor Source | | | |
| 05 | Required Maximum U-factor | | | |
| 06 | Weighted Average (Yes/No) | | | |
| 07 | Comments | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



J. Space Conditioning (SC) Systems – Heating/Cooling (Section 150.2(b))

Alterations to space conditioning systems shall be exempt from field verification and diagnostic testing requirements as prerequisite for use of the CF1R-ADD-02 and CF2R-ADD-02 compliance documents. If new space conditioning systems are installed or existing systems are altered and are not exempt from field verification and diagnostic testing, then a CF1R-ALT-02 shall be completed and registered with an ECC Provider Data Registry. In each row below for each space conditioning system, check the box that indicates the exemption from field verification compliance:

- a: space conditioning system was not altered;
- b: less than 25 feet (ft) of ducts were added or replaced;
- c: (exempt from duct leakage testing) if: the existing duct system was insulated with asbestos;
- d: (exempt from duct leakage testing) if: the existing duct system was previously tested and passed by an ECC-Rater.

| 01 | 02 | 03 | | | |
|----------------------------------|-----------------------------------|---------------------------------|----------------------------|----------------------------|----------------------------|
| SC System Identification or Name | SC System Location or Area Served | Exemption from ECC Verification | | | |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |
| | | <input type="checkbox"/> a | <input type="checkbox"/> b | <input type="checkbox"/> c | <input type="checkbox"/> d |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



K. Water Heating Systems (Section 150.2(b)1H)

List water heaters and boilers for both domestic hot water (DHW) heaters and hydronic space heating.

Options:

1. Gas or propane water heating system; or
2. A single heat pump water heater. The storage tank shall not be located outdoors and shall be placed on an incompressible, rigid insulated surface with a minimum thermal resistance of R-10. The water heater shall be installed with a communication interface that meets either the requirements of Section 110.12(a) or has an ANSI/CTA-2045-B communication port; or
3. A single heat pump water heater that meets the requirements of NEEA Advanced Water Heater Specification Tier 3 or higher; or
4. If no natural gas is connected to the existing water heater location, a consumer electric water heater (Heat Pump Water Heater or Electric Resistance)

Table K-1

| Field | Field Name | Data Entry |
|-------|--|--|
| 01 | Is natural gas connected to the existing water heater? | <input type="checkbox"/> Yes <input type="checkbox"/> No |

Table K-2

| Field | Field Name | Data Entry 1 | Data Entry 2 | Data Entry 3 |
|-------|-------------------------------------|--------------|--------------|--------------|
| 02 | Water Heating System ID or Name | | | |
| 03 | System Option (from §150.2(b)1Hiii) | | | |
| 04 | Water Heater Type | | | |
| 05 | Fuel Type | | | |
| 06 | # of Water Heaters in System | | | |

PRESCRIPTIVE RESIDENTIAL ALTERATIONS THAT DO NOT REQUIRE ECC FIELD VERIFICATION



| | |
|---|---|
| <p>Documentation Author's Declaration Statement</p> <p>1. I certify that this Certificate of Compliance documentation is accurate and complete.</p> | <p>Author Name</p> <p>Author Signature</p> <p>Date Signed</p> <p>Company Name</p> <p>CEA/AEA/ECC Certification ID</p> <p>Address</p> <p>City/State/Zip</p> <p>Phone</p> |
| <p>Responsible Person's Declaration Statement</p> <p>I certify the following under penalty of perjury, under the laws of the State of California:</p> <ol style="list-style-type: none"> The information provided on this Certificate of Compliance is true and correct. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer). The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. I understand that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building and shall be made available to the enforcement agency for all applicable inspections. I will take the necessary steps to fulfill this requirement. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy. I will take the necessary steps to fulfill this requirement. | <p>Responsible Name</p> <p>Responsible Signature</p> <p>Date Signed</p> <p>Company Name</p> <p>License No.</p> <p>Address</p> <p>City/State/Zip</p> <p>Phone</p> |

For assistance or questions regarding the Energy Standards, contact the Energy Hotline at: 1-800-772-3300.

CF1R-ALT-05-E User Instructions

NOTE: If more space is needed, print a duplicate page and fill in.

Minimum requirements for prescriptive alteration compliance can be found in Building Energy Efficiency Standards Section 150.2(b)1.

Completing these forms will require that you have the Reference Appendices for the 2025 Building Energy Efficiency Standards. This document contains the Joint Appendices which are used to determine climate zone and to complete the section for opaque surfaces. When the term CF1R is used it means the CF1R-ALT-05. Worksheets are identified by their entire name and subsequently by only the worksheet number, such as ENV-02.

Instructions for sections with column numbers and row letters are given separately.

If any part of the alteration does not comply, prescriptive compliance fails, in which case the performance compliance approach must be used in an attempt to achieve compliance.

A. General Information

1. Project Name: Identifying information, such as owner's name.
2. Date Prepared: Date of document preparation.
3. Project Location: Legal street address of property or other applicable identifying information.
4. Building Front Orientation: Building front orientation expressed in degrees, where North = 0, East = 90, South = 180, and West = 270. Indicate cardinal if it is a subdivision project built in multiple orientations. The standards (section 100.1) include the following additional details for determining orientation:
 - Cardinal covers all orientations (for buildings that will be built in multiple orientations);
 - North is oriented to within 45 degrees of true north, including 45 degrees east of north;
 - East is oriented to within 45 degrees of true east, including 45 degrees south of east;
 - South is oriented to within 45 degrees of true south, including 45 degrees west of south;
 - West is oriented to within 45 degrees of true west, including 45 degrees north of west.
5. CA City: Legal city/town of property.
6. Number of Altered Dwelling Units: 1 for single-family
7. Zip Code: 5-digit zip code for the project location (used to determine climate zone).
8. Fuel Type: Natural Gas, Liquefied Propane Gas, or Electricity.
9. Climate Zone: From Reference Appendices, Joint Appendix, JA2.1.1.
10. Total Conditioned Floor Area: Enter the new conditioned floor area in square feet (ft²), as measured from the outside of exterior walls of the dwelling unit or building being altered.
11. Building Type: Single Family (includes duplex).
12. Slab Area: Area of the first floor slab (if any) in square feet (ft²).
13. Project Scope: Insulation, Roof Replacement, Fenestration/Glazing, Heating System, Cooling System, Duct System, and/or Water Heating System alteration.

B. Opaque Surface Details (Section 150.2(b)1)

1. Tag/ID: A label (if any) from the plans, such as A1.4 or wall.
2. Assembly Type: Roof, Ceiling, Wall, Floor or Attic.
3. Frame Type: Wood or Metal.
4. Frame Depth: Nominal dimensions of framing material in inches such as 2x4, 2x6, 2x8, 2x10.
5. Frame Spacing: 16,24, or 48 inches on center.
- 6a. Proposed Cavity R-value: Insulation installed between framing.

- 6b. Proposed Continuous Insulation R-value: R-value of rigid or continuous insulation (not interrupted by framing). See Table 4.3.4. of Reference Appendices, Joint Appendix, for metal frame construction.

NOTE: Section 110.8(d) specifies that if adding insulation to an existing attic, the resulting attic insulation must total R-22. However, the amount of insulation required is limited to the amount of room available for insulation without conflicting with Building Code Section 1203.2.

7. Proposed U-factor: The U-factor for the entire assembly.
8. Required U-factor: From the requirements in Sections 110.8 and 150.0.
9. Comments: Any notes regarding location, unique conditions, or attachments.

C. Opaque Surface Details – Non-framed

1. Tag/ID: A label (if any) from the plans, such as A1.4 or wall.
2. Assembly Type: Roof or Wall.
3. Assembly Material: SIP OSB, SIP I-Joist, SIP Single 2x, SIP Double 2x, see JA4 for guidance.
4. Thickness: Thickness in inches.
5. Proposed Core Insulation R-value: Insulation installed within the materials or on the inside. See Reference Appendices, Joint Appendix, JA4 for guidance.
6. Proposed Continuous Insulation R-value: Insulation installed on the exterior. See Reference Appendices, Joint Appendix, JA4 for guidance.
7. Proposed U-factor: Assembly U-factor from Reference Appendices, Joint Appendix, JA4 or CF1R-ENV-02. Must be less than or equal to Column 10.
8. Required U-factor from Table 150.1-A: Based on assembly type and climate zone.
9. Comments: Any notes regarding location, unique conditions, or attachments.

D. Opaque Surface Details – Masonry/Mass Walls

1. Tag/ID: A label (if any) from the plans, for example, A1.4 or wall.
2. Above or Below Grade?: Indicate whether the mass wall is installed above grade or below grade.
3. Masonry/Mass Wall Type: Clay Brick, Clay Hollow Unit, Concrete Masonry Unit (CMU) Light Weight, Concrete Masonry Unit (CMU) Medium Weight, Concrete Masonry Unit (CMU) Normal Weight, Concrete, Insulating Concrete Form (ICF). See Reference Appendices, Joint Appendix, JA4 for guidance.
4. Masonry/Mass Wall Thickness: Thickness (in inches) of mass.
- 5-6. Proposed Exterior Insulation R-value or U-factor: Enter the R-value or U-factor of proposed insulation on the outside surface of the mass wall. See Reference Appendices, Joint Appendix, JA4 for guidance. Use the same descriptor (R-value or U-factor) throughout Table D.

- 7-8. Proposed Interior Insulation R-value or U-factor: Enter the R-value or U-factor of proposed insulation on the inside surface of the mass wall. See Reference Appendices, Joint Appendix, JA4 for guidance. Use the same descriptor (R-value or U-factor) throughout Table D.
- 9-10. Required Exterior Insulation R-value or U-factor: The required R-value or U-factor (whichever descriptor was selected in Column 7 or 8) for exterior insulation will be completed based on the Table 150.1-A requirements for the wall type.
- 11-12. Required Interior Insulation R-value or U-factor: The required R-value or U-factor (whichever descriptor was selected in Column 9 or 10) for interior insulation will be completed based on the Table 150.1-A requirements for the wall type.

E. Roof Replacement (Section 150.2(b)1I)

When 50% or more of the roof is being replaced the roofing requirements are triggered. Any areas of roof covered by building integrated photovoltaic panels and solar thermal panels are exempt, but the area of roof not covered by photovoltaic panels would still need to meet any applicable cool roof requirements. Additionally, there are many alternatives/exceptions to when a cool roof is required.

When the roof is steep-sloped (pitch greater than or equal to 2:12) the roof requirements include a cool roof in climate zones 4 and 8-15. The minimum requirement is 0.20 Aged Solar Reflectance, 0.75 Thermal Emittance, or a minimum SRI of 16.

1. Tag/ID: A label, if any, from the plans, for example R-1.
2. Method of Compliance: Indicate if the method of compliance is going to be based on Aged Solar Reflectance and Thermal Emittance, the Solar Reflectance Index (SRI), or an Exception.
3. Roof Pitch: Expressed as 4:12, for example, which means the roof rises 4 foot within a span of 12 feet. When roofs have multiple pitches the requirements are based on the pitch of 50 percent or more of the roof.
4. Exception: If meeting one of the exceptions. Indicate which exception is, or will be, met.

EXCEPTIONS AND ALTERNATIVES FOR STEEP SLOPE ROOFS:

- (a) Mass roof 25 pounds per square foot (lbs/ft²) or greater (such as sod roof);
- (b) Roof has ceiling assemblies with a U-factor less than or equal to 0.025 or R-38 insulation;
- (c) Roof has a radiant barrier not installed directly above spaced sheathing meeting 150.1(c)2;
- (d) R-2 continuous insulation above the roof deck.

In climate zones 4 and 6-15, when there is a low-sloped roof (pitch less than 2:12) the cool roof requirements are for a minimum Aged Solar Reflectance of 0.63, a minimum 0.75 Thermal Emittance, or a minimum SRI of 75.

EXCEPTIONS AND ALTERNATIVES FOR LOW SLOPE ROOFS:

- (a) Mass roof 25 pounds per square foot (lbs/ft²) or greater (uncommon situation such as sod roof);
- (b) Roof deck installation trade off—by installing roof deck insulation, a lower aged solar reflectance is required: In Climate Zones 6 and 7 R-2 (0.60), R-4 (0.55), R-6 (0.50), R-8 (0.45), R-10 (no requirement); In Climate Zones 2, 4 and 8-15 R-16 (0.60), R-18 (0.55), R-20 (0.50), R-24 (no requirement).

NOTE: If one of the exceptions above has been selected then the rest of Section C. is not required.

5. CRRC Product ID Number: The CRRC Product ID Number is obtained from the [Cool Roof Rating Council’s Rated Product Directory](#). Products are listed by manufacturer, brand, type of installation, roofing material, and color, as well as product performance.
6. Product type: See [Cool Roof Rating Council’s directory](#). Generally product types include single-ply roof, wood shingles, asphalt roof, metal roof, tile roof.
7. R-value Deck Insulation: If one of the exceptions selected includes adding roof deck insulation, indicate the R-value of the insulation.
8. Proposed Initial Solar Reflectance: Based on the product chosen from the [Cool Roof Rating Council’s Rated Product Directory](#). If using default assumption indicate N/A since the Aged Solar Reflectance is available.
9. Proposed Aged Solar Reflectance: Value is from the [Cool Roof Rating Council’s Rated Product Directory](#). If the aged value is not available, calculate the Aged Solar Reflectance using the Solar Reflectance Index (SRI) Calculator located on the California Energy Commission website or the aging equation $\rho_{aged}=[0.2+\beta[\rho_{initial}-0.2]]$, where $\rho_{initial}$ = the initial solar reflectance and soiling resistance β is listed by product type below.

VALUES OF SOILING RESISTANCE β BY PRODUCT TYPE

| Product Type | CRRC Product Category | β |
|-----------------------|-----------------------------|---------|
| Field-Applied Coating | Field-Applied Coating | 0.65 |
| Other | Not A Field-Applied Coating | 0.70 |

10. Proposed Thermal Emittance: From the product specification default value. If using a calculated Solar Reflectance Index (SRI) place the Thermal Emittance used to calculate SRI.
11. Proposed Solar Reflectance Index (SRI): It is optional to meet the SRI but if chosen to do so, use the Solar Reflectance Index (SRI) Calculator found on the [California Energy Commission website](#).
12. Minimum Required Aged Solar Reflectance: Based on climate zone and roof slope.
13. Minimum Required Thermal Emittance: Based on climate zone and roof slope.
14. Minimum Required SRI: Based on climate zone and roof slope.

NOTE: If the cool roofing requirements will be met by a liquid field applied coating, Section 110.8(i)4 requires the coating be applied across the entire roof surface and meet the dry mil thickness or coverage recommended by the manufacturer.

F. Fenestration/Glazing Allowed Areas and Efficiencies (Section 150.2(b)1)

The Alteration and Fenestration Type will affect how the standards apply and whether the fenestration area is limited. Percentages are determined as Conditioned Floor Area (CFA) x 0.20 = total square footage (ft²) of fenestration allowed (20 percent). Depending on the climate zone, if west-facing fenestration is limited (in climate zones 2, 4, 6-15), it is limited to a maximum of 5 percent. The overall total fenestration area is limited to 20 percent, not 25 percent. Fenestration areas are expressed in square feet, not square inches.

1. Alteration Type: Indicate the type of fenestration alteration - adding fenestration/glazing, replacing fenestration/glazing, replacing fenestration/glazing less than or equal to 75 ft² window, adding fenestration/glazing less than or equal to 16 ft² skylight and or replacing fenestration/glazing skylights

2. Maximum Allowed Fenestration Area for All Orientations (ft²): The maximum allowed fenestration area is 20 percent. Depending on the type of fenestration and the alteration type, this field may have values such as 75 square feet (ft²) or 16 ft².
3. Maximum Allowed West-Facing Fenestration Area Only: The Maximum Allowed West-Facing Fenestration Area is 5 percent of the conditioned floor area (used in climate zones 2, 4, and 6-15).

NOTE: (1) If adding fenestration/glazing less than or equal to 16 ft² skylight, enter NA
 (2) West includes any vertical fenestration oriented to within 45 degrees of true west, including 45 degrees south of west. For skylights, west also includes any skylight area facing any direction with a pitch of less than 1:12

4. Existing Fenestration Area for All Orientations: Enter the area, in square feet, of the existing fenestration/glazing.
 Existing West-Facing Fenestration Area: Enter the area, in square feet (ft²), of the existing west-facing fenestration/glazing. If project has no existing west-facing fenestration then enter "0".

5. Maximum Allowed U-factor: Maximum U-factor from Table 150.1-A, Package A.

NOTE:

(1) If meeting Exception 1 to Section 150.2(b)1B (replacing less than or equal to 75 square feet (ft²) windows), enter 0.40.

(2) If meeting Exception 2 to Section 150.2(b)1B (replacing skylights), enter 0.40.

6. Maximum Allowed SHGC: Maximum solar heat gain coefficient (SHGC) from Table 150.1-A.

NOTE:

(1) If meeting Exception 1 to Section 150.2(b)1B, (replacing less than or equal to 75 square feet (ft²) windows), enter 0.35 in Climate Zones 2, 4, and 6- through 15.

(2) If meeting Exception 2 to Section 150.2(b)1B (replacing skylights), enter 0.30.

(3) If meeting Exception 3 to Section 150.2(b)1B (~~vertical fenestration shall have a maximum SHGC value no greater than 0.23 in~~ Climate Zone 15.), enter no greater than 0.23.

7. Comments: Note any special location or comment here.

G. Fenestration/Glazing Proposed Areas and Efficiencies - Add (Section 150.2(b)1A)

1. Tag/ID: A label (if any) from the plans, such as W1.
2. Fenestration Type: Indicate the type of fenestration construction e.g., Fixed Window, Operable Window, or Skylight.

NOTE: Doors with glazing are counted in one of two ways. A door with 25 percent or more glazing is considered a glazed door and is counted as the entire door area. A door with less than 25 percent glazing can be counted as the entire door area or can be calculated as the actual glass area with a 2-inch (0.17 ft²) frame all around.

3. Frame type: Metal, metal thermal break, or nonmetal.
4. Dynamic Glazing: Indicate if the fenestration has integrated shading device, chromogenic glazing or none for no dynamic glazing. Chromogenic glazing shall be considered separately from other fenestration types.
5. Orientation (North, East, South, West): The definitions in the Energy Standards include these specific details -
 - North is oriented to within 45 degrees of true north, including 45 degrees east of north;

- East is oriented to within 45 degrees of true east, including 45 degrees south of east;
- South is oriented to within 45 degrees of true south, including 45 degrees west of south;
- West is oriented to within 45 degrees of true west, including 45 degrees north of west.

NOTE: Skylights in a roof pitch greater than 1:12 can be included as facing the same orientation as that portion of the roof angle. If the skylight is in a roof with a pitch less than 1:12, the skylight is assumed to face west.

6. Number of Panes: Indicate the number of panes for each Tag/ID; is it single, double, or triple pane window?
7. Proposed Fenestration Area (ft²): Indicate the area in square feet (ft²) of each exterior fenestration type, excluding west-facing fenestration.
8. Proposed West Facing Fenestration Area (ft²): In climate zones 2, 4, 6-15, indicate the area in square feet (ft²) of each exterior west-facing fenestration type separately.
9. Proposed U-factor: Enter (a) the National Fenestration Rating Council (NFRC) U-factor based on the proposed brand and type of fenestration using [NFRC certified values](#), (b) the default value from Table 110.6-A or Equation NA6-1, or (c) the weighted average U-factor calculated on form CF1R-ENV-02-E.

For the exceptions, up to 3 square feet (ft²) of tubular skylights and up to 3 ft² of glazing in a door enter N/A, and for up to 16 ft² of skylight, enter 0.40. If any products (other than the exceptions) have a higher U-factor than required by Package A, first complete a form CF1R-ENV-02 to calculate the area-weighted average U-factor and attach it to this CF1R.

NOTE: Dynamic glazing is a glazing system that changes its performance U-factor and SHGC based on the physical environment. Dynamic glazing includes chromogenic glazing or integrated shading systems (this does not include internally or externally mounted shading devices). If using dynamic glazing, use the lowest tested U-factor and solar heat gain coefficient (SHGC) in Columns 9 and 11.

10. Proposed U-factor Source: National Fenestration Rating Council (NFRC), Table 110.6-A, Equations NA6-1, or Area-Weighted Average Worksheet (ENV-02). The source of the U-factor data for the fenestration product.
11. Proposed SHGC: In climate zones 2, 4, 6-15 enter the solar heat gain coefficient (SHGC) from (a) National Fenestration Rating Council (NFRC), or (b) default value from Table 110.6-B or Equation NA6-2, or (c) the weighted average SHGC calculated on form CF1R-ENV-02.

For the exceptions – up to 3 square feet (ft²) of tubular skylights and up to 3ft² of glazing in a door, enter N/A. If any products (other than the exceptions) have a higher SHGC than required by Table 150.1-A, first complete a form CF1R-ENV-02 to calculate the area-weighted average SHGC and attach it to this CF1R.

12. Proposed SHGC Source: National Fenestration Rating Council (NFRC), Table 110.6-A, Equations NA6-1, or Area-Weighted Average Worksheet (ENV-02). The source of the U-factor data for the fenestration product.

13. Exterior Shading Device: If exterior shading devices are used to meet the SHGC requirement, indicate the type of device (from Table S-1 of CF1R-ENV-03 Solar Heat Gain Coefficient Worksheet) and attach an ENV-03.

NOTES:

- (1) An exterior shading device is not used for products with an NFRC rated U-factor and SHGC; based on a factory integrated shading device.
- (2) If using an overhang for south-facing glazing, the glazing must be fully shaded at solar noon on August 21 and substantially exposed to direct sunlight at solar noon on December 21 (see Residential Compliance Manual, Section 3.3.6.3).

14. Combined SHGC from CF1R-ENV-03: If exterior shading devices are combined with the solar heat gain coefficient (SHGC) value of the fenestration to meet the prescriptive SHGC requirements (as indicated by a value in column E. 13), indicate the SHGC calculated on form CF1R-ENV-03 and attach the form for each window with an exterior shading device.

To determine compliance with allowable fenestrations areas and efficiencies, complete rows 15-32.

15. Total Proposed Fenestration Area: Enter the sum of the existing (F04a) and proposed fenestration areas for all orientations (G07 + G08). For project scopes: Add Fenestration/Glazing less than or equal to 16 ft², enter NA.

16. Maximum Allowed Fenestration Area: Enter the maximum allowed fenestration area for all orientations, from F02.

17. Is the Total Proposed Fenestration Area (G15) less than or equal to the Maximum Allowed Fenestration Area: Indicate Yes if the Total Proposed Fenestration Area is less than or equal to the Maximum Allowed Fenestration Area. If No, the project fails prescriptive compliance – specified fenestration areas must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G15 equals N/A.

Note: If Total Proposed Fenestration Area equals NA, Design Complies - Indicate Yes.

18. Total Proposed West-Facing Fenestration Area: Enter the sum of the existing (F04b) and proposed west-facing fenestration areas (G08). For project scope: Add Fenestration/Glazing less than or equal to 16 ft², enter NA.

19. Maximum Allowed West-Facing Fenestration Area: Enter the maximum allowed west-facing fenestration area only, from F03.

20. Is the Total Proposed Fenestration Area less than or equal to the Maximum Allowed West-Facing Fenestration Area: Indicate Yes if the Total Proposed West-Facing Fenestration Area is less than or equal to the Maximum Allowed West-Facing Fenestration Area. If No, the project fails prescriptive compliance – specified west-facing fenestration areas must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G18 equals N/A.

Note: If Total Proposed Fenestration Area equals NA, Design Complies - Indicate Yes.

21. Proposed Fenestration U-factor (Windows): If necessary, report the area-weighted average U-factor from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from column G09 if G02 fixed window or operable window and G09 are less than or equal to 0.30. If G02 does not equal fixed window or operable window then report N/A

22. Required Fenestration U-factor (Windows): Enter the Maximum Allowed U-factor (F05a).

23. Is the Proposed Fenestration U-factor less than or equal to the Required Fenestration U-factor: Indicate Yes if the Proposed Fenestration U-factor is less than or equal to the Required Fenestration U-factor. If No, the project fails prescriptive compliance – specified fenestration U-factor must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G21 equals N/A.
24. Proposed Fenestration SHGC (Windows): If necessary, report the area-weighted average SHGC from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from column G11 or G14.
25. Required Fenestration SHGC (Windows): Enter the Maximum Allowed solar heat gain coefficient (SHGC) (F06a).
26. Is the Proposed Fenestration SHGC less than or equal to the Required Fenestration SHGC: Indicate Yes if the Proposed Fenestration SHGC is less than or equal to the Required Fenestration SHGC. If No, the project fails prescriptive compliance – specified fenestration SHGC must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G24 equals N/A.
27. Proposed Fenestration U-factor (Skylights): If necessary, report the area-weighted average U-factor from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from column G09.
28. Required Fenestration U-factor (Skylights): Enter the Maximum Allowed U-factor (F05b).
29. Is the Proposed Fenestration U-factor less than or equal to the Required Fenestration U-factor: Indicate Yes if the Proposed Fenestration U-factor is less than or equal to the Required Fenestration U-factor. If No, the project fails prescriptive compliance – specified fenestration U-factor must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G29 equals N/A.
30. Proposed Fenestration SHGC (Skylights): If necessary, report the area-weighted average solar heat gain coefficient (SHGC) from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from column G11 or G14.
31. Required Fenestration SHGC (Skylights): Enter the Maximum Allowed solar heat gain coefficient (SHGC) (F06b).
32. Is the Proposed Fenestration SHGC less than or equal to the Required Fenestration SHGC: Indicate Yes if the Proposed Fenestration solar heat gain coefficient (SHGC) is less than or equal to the Required Fenestration SHGC. If No, the project fails prescriptive compliance – specified fenestration SHGC must be reduced, or compliance may be attempted using the performance approach. Or report N/A if G30 equals N/A.

H. Fenestration/Glazing Proposed Areas and Efficiencies – Replace (Section 150.2(b)1B)

1. Tag/ID: A label (if any) from the plans, such as W1.
2. Fenestration Type: Indicate the type of fenestration construction (e.g., Fixed Window, Operable Window, or Skylight).

NOTE: Doors with glazing are counted in one of two ways. A door with 25 percent or more glazing is considered a glazed door and is counted as the entire door area. A door with less than 25 percent glazing can be counted as the entire door area or can be calculated as the actual glass area with a 2-inch (0.17 ft²) frame all around.

3. Frame Type: Metal, metal thermal break, or nonmetal.
4. Dynamic Glazing: Indicate if the fenestration has integrated shading device, chromogenic glazing or none for no dynamic Glazing.

NOTE: Chromogenic glazing shall be considered separately from other fenestration types.

5. Orientation (North, East, South, West): The definitions in the Energy Standards include these specific details -
 - North is oriented to within 45 degrees of true north, including 45 degrees east of north;
 - East is oriented to within 45 degrees of true east, including 45 degrees south of east;
 - South is oriented to within 45 degrees of true south, including 45 degrees west of south;
 - West is oriented to within 45 degrees of true west, including 45 degrees north of west.

NOTE: Skylights in a roof pitch greater than 1:12 can be included as facing the same orientation as that portion of the roof angle. If the skylight is in a roof with a pitch less than 1:12, the skylight is assumed to face west.

6. Area Removed (ft²): Enter the area, in square feet (ft²), of the fenestration/glazing being removed.
7. Area Added (ft²): Enter the area, in square feet (ft²), of the fenestration/glazing being added.
8. Net Added Area (ft²): The difference between the Area Added and the Area Removed.
9. Proposed U-factor: Enter (a) the National Fenestration Rating Council (NFRC) U-factor based on the proposed brand and type of fenestration using [NFRC certified values](#), (b) the default value from Table 110.6-A, (c) Equation NA6-1, or (d) the area-weighted average U-factor calculated on form CF1R-ENV-02-E, Area-Weighted Average Calculation Worksheet.

For the exceptions, up to 3 square feet (ft²) of tubular skylights and up to 3 ft² of glazing in a door enter N/A, and for up to 16 ft² of skylight, enter 0.40. If any products (other than the exceptions) have a higher U-factor than required by Package A, first complete an ENV-02 to calculate a weighted average U-factor and attach it to this CF1R.

NOTE: Dynamic glazing is a glazing system that changes its performance U-factor and solar heat gain coefficient (SHGC) based on the physical environment. Dynamic glazing includes chromogenic glazing or integrated shading systems (this does not include internally or externally mounted shading devices). If using dynamic glazing, use the lowest tested U-factor and SHGC in Columns 9 and 11.

10. Proposed U-factor Source: National Fenestration Rating Council (NFRC), Table 110.6-A, Equations NA6-1, or Area-Weighted Average Worksheet (ENV-02). The source of the U-factor data for the fenestration product.
11. Proposed SHGC: In climate zones 2, 4, 6-15 enter the solar heat gain coefficient (SHGC) from (a) National Fenestration Rating Council (NFRC), (b) default value from Table 110.6-B, (c) Equation NA6-2, or (d) the weighted average SHGC calculated on form CF1R-ENV-02.

For the exceptions – up to 3 square feet (ft²) of tubular skylights and up to 3ft² of glazing in a door, enter N/A; up to 16ft² of skylight, enter 0.30. If any products (other than the exceptions) have a higher SHGC than required by Table 150.1-A or Table 150.1-B, first complete a form CF1R-ENV-02 to calculate the area-weighted average SHGC and attach it to this CF1R.

12. Proposed SHGC Source: National Fenestration Rating Council (NFRC), Table 110.6-B, Equations NA6-2, or Area-Weighted Average Worksheet (ENV-02). The source of the solar heat gain coefficient (SHGC) data for the fenestration product.
13. Exterior Shading Device: If exterior shading devices are used to meet the solar heat gain coefficient (SHGC) requirement, indicate the type of device (from Table S-1 of CF1R-ENV-03 Solar Heat Gain Coefficient Worksheet) and attach an ENV-03.

NOTES: (1)An exterior shading device is not used for products with a National Fenestration Rating Council (NFRC) rated U-factor and solar heat gain coefficient (SHGC); based on a factory integrated shading device.
(2)If using an overhang for south-facing glazing, the glazing must be fully shaded at solar noon on August 21 and substantially exposed to direct sunlight at solar noon on December 21 (see Residential Manual, Section 3.5.5).

14. Combined SHGC from CF1R-ENV-03: If exterior shading devices are combined with the solar heat gain coefficient (SHGC) value of the fenestration to meet the prescriptive SHGC requirements (as indicated by a value in column F. 13), indicate the SHGC calculated on form CF-1R-ENV-03 and attach the form for each window with an exterior shading device.

To determine compliance with allowable fenestration areas, complete rows 15-30.

15. Net Added West-facing Fenestration Area (H08): If limited, enter the total amount of west-facing fenestration ONLY that will be added to the dwelling unit when alterations are complete.
16. Is Net Added Fenestration Area (H15) less than or equal to 0 for west-facing fenestration? Indicate Yes or No. If No, the project fails prescriptive compliance – specified west-facing fenestration areas must be reduced, or compliance may be attempted using the performance approach.
17. Net Added Fenestration Area (all orientations) (H08): This field is to show the net area of added fenestration for all orientations.
18. Is Net Added Fenestration Area (H17) less than or equal to 0 for all orientations? Indicate Yes or No. If No, the project fails prescriptive compliance – specified fenestration areas must be reduced, or compliance may be attempted using the performance approach.
19. Proposed Fenestration U-factor (Windows): If necessary, enter the area-weighted average U-factor from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from H09.
20. Required Fenestration U-factor (Windows): From Section F., report the value of column F05a.

21. Is the Proposed Fenestration U-factor less (H19) than or equal to the Required Fenestration U-factor (H20)? Indicate Yes or No. If No, the project fails prescriptive compliance – specified fenestration U-factor must be reduced, or compliance may be attempted using the performance approach. Or report N/A if H19 equals N/A.
22. Proposed Fenestration SHGC (Windows): If necessary, enter the area-weighted average solar heat gain coefficient (SHGC) from the complete CF1R-ENV-02. Otherwise, report the single largest associated value from columns H11 or H14. Otherwise report N/A if H11 or H14 equals N/A.
23. Required Fenestration SHGC (Windows): From Section F., report the value of column F06a.
24. Is the Proposed Fenestration SHGC (H22) less than or equal to the Required Fenestration SHGC (H23), or (H23) equals NA? Indicate Yes or No. If No, the project fails prescriptive compliance – specified fenestration SHGC must be reduced, or compliance may be attempted using the performance approach. Or report N/A if H22 equals N/A.
25. Proposed Fenestration U-factor (Skylights): If necessary, enter the area-weighted average U-factor from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from H09. Otherwise report N/A if H02 equals N/A.
26. Required Fenestration U-factor (Skylights): From Section F., report the value of column F05b.
27. Is the Proposed Fenestration U-factor (H25) less than or equal to the Required Fenestration U-factor (H26)? Indicate Yes or No. If No, the project fails prescriptive compliance – specified fenestration U-factors must be reduced, or compliance may be attempted using the performance approach. Or report N/A if H25 equals N/A.
28. Proposed Fenestration SHGC (Skylights): If necessary, enter the area-weighted average solar heat gain coefficient (SHGC) from the completed CF1R-ENV-02. Otherwise, report the single largest associated value from columns (H11) or (H14), Or report N/A if (H11), or (H14) equals NA. Otherwise report N/A if H02 equals N/A.
29. Required Fenestration SHGC (Skylights): From Section F., report the value of column F06b.
30. Is the Proposed Fenestration SHGC (H28) less than or equal to the Required Fenestration SHGC (H29)? Indicate Yes or No. If No, the project fails prescriptive compliance – specified fenestration SHGC must be reduced, or compliance may be attempted using the performance approach. Or report N/A if H28 equals N/A.

I. Opaque Swinging Doors to Exterior

1. Tag/ID: Provide a name or designator for each unique door. This designator should be used consistently throughout the plan set (elevations, door schedules, etc.)
2. Area: Calculated area in square feet (ft²) for each unique door.
3. Proposed U-factor: Enter the proposed U-factor. If value is greater than 0.20, column 06 will autocomplete as Yes.
4. Proposed U-factor Source: National Fenestration Rating Council (NFRC) or Reference Appendices, Joint Appendix, Table 4.5.1s, 110.6-A and 110.6-B, Equations NA6-1 and NA6-2, or Area-Weighted Average Worksheet (CF1R-ENV-02).
5. Required Maximum U-factor. This field will always be 0.20.
6. Weighted Average: If column 03 is greater than 0.20 U-factor, attach form CF1R-ENV-02-E.
7. Comments: Any notes regarding location, unique conditions, or attachments.

J. Space Conditioning (SC) Systems – Heating/Cooling

Requirements of the Standards apply to a heating and cooling system alteration based on the type of alteration and the system type (Section 150.2(b)1). A completely new system will meet all mandatory and prescriptive requirements, which vary by climate zone (based on Section 150.2(b)1C).

When parts of a system are replaced, it may trigger some of the same requirements that apply to new systems and duct alterations. A Certificate of Compliance for Alterations to Space Conditioning Systems (CF1R-ALT-02) is required for each dwelling unit with a space conditioning system alteration.

1. Space Conditioning (SC) System Identification or Name: Name of the space conditioning (SC) system or any other identifying name.
2. Space Conditioning (SC) System Location or Area Served: Zone, or area, served by the space conditioning (SC) system.
3. Exemption from field Verification: Section 150.2(b)1E
 - a. Space Conditioning (SC) System was not altered.
 - b. Duct systems with less than 25 linear feet in unconditioned spaces as determined by visual inspection.
 - c. Existing duct systems constructed, insulated or sealed with asbestos
 - d. Duct systems that have been documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Appendices, Residential Appendix, RA3.1.

K. Water Heating Systems

Water heating compliance for an alteration is described in Section 150.2(b)1H.

Options:

1. Gas or propane water heating system; or
 2. A single heat pump water heater. The storage tank shall not be located outdoors and shall be placed on an incompressible, rigid insulated surface with a minimum thermal resistance of R-10. The water heater shall be installed with a communication interface that meets either the requirements of Section 110.12(a) or has a ANSI/CTA-2045-B communication port; or
 3. A single heat pump water heater that meets the requirements of NEEA Advanced Water Heater Specification Tier 3 or higher; or
 4. If no natural gas is connected to the existing water heater location, a consumer electric water heater
1. Is natural gas connected to the existing water heater? Yes or No.
 2. System Option (from §150.2(b)1Hiii): Indicate the prescriptive option, pick from list: 2, 3, or 4 if K01 equal No. Otherwise pick from list: 1, 2, 3 if K01 equal Yes.
 3. Water Heater Type: if K03 is 1, then value equal gas or propane water heater (Storage or instantaneous); if K03 is 2, then value equal heat pump water heater; if K03 is 3, then value equal NEEA Tier 3 or higher heat pump water heater; if K03 is 4, then value equal Consumer electric water heater (Heat Pump Water Heater or Electric Resistance)
 4. Fuel Type: If K03 is 1, then picks from list: Natural gas, Propane; and if K03 equal 2 or 3, then pick Heat Pump; and if K03 equal 3, then pick Electricity
 5. Number of Water Heaters in System: Enter the total number of water heaters for each system.

Documentation Declaration Statements

1. The person who prepared the CF1R will sign and complete the fields for their name, company (if applicable), address, phone number, certification information (if applicable), date and signature.
2. The person who is assuming responsibility for the project being built to comply with Title 24, Part 6, will complete the fields for their name, company (if applicable), address, phone number, license number (if applicable), date and signature (may be electronic).